



# 품질시험·검사성적서

1. 성적서 번호 : CMT2018 - 1962  
 2. 의뢰인 업체명 : (주)유니온  
 주소 : 서울특별시 중구 소공로 94(OCI빌딩 13층)  
 성명 : 강병호  
 3. 성과이용목적 : 품질관리용  
 4. 시료명 : 발수제(유니온 발수제 301)  
 5. 접수일자 : 2018년 02월 28일  
 6. 발급일자 : 2018년 05월 08일

## 시험결과

연번	시험·검사종목	단위	시험·검사방법	시험·검사결과
1	발수성(흡수비)	-	KICM - QA - 905 : 2002	0.15
2	침투 깊이	mm		0.7

담당자 : 최 환  
 Tel : 031-646-0810

기술책임자 : 신도철  
 Tel : 031-646-0801

- ※ 비 고 : 1. 이 시험성적서는 당초 의뢰자가 제출한 시료 및 시료명으로 시험한 결과로서 전체 제품에 대한 품질을 보증 하지는 않습니다.  
 2. 이 성적서는 홍보, 선전, 광고 및 소송용으로 사용될 수 없으며, 용도 이외의 사용을 금합니다.  
 3. 이 성적서의 원본 진위확인은 한국에스지이에스 온라인 성적서 조회 홈페이지(<http://e-checking.kr.sgs.com/construction/>)에서 열람이 가능합니다.



## 한국에스지이에스(주) 건설시험연구원

주소 : 경기도 화성시 동탄면 동탄산단10길 20 전화번호 (031)669-0600

유의사항 : 기술책임자의 성명과 서명이 없는 경우에는 결과에 대한 보증을 할 수 없습니다.

페이지 1 / 1

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.  
 KQP-2510-001-F07 (07)

